

January 6, 2016

Addendum No. 3

17-05B - Sunset Point Park Playground Fence

This addendum shall modify and become a part of the original Proposal Document. The following clarifications, changes, additions and/or deletions are hereby made part of the Contract Documents for **Bid No. 17-05B - Sunset Point Park Playground Fence**


Q: = Question
A: = Answer

TO ALL PROSPECTIVE BIDDERS:

1. The new bid opening date for this project is 01/19/2016 at 3:00 PM.
2. Please add the following information to the bid:
 - The Powder Coat Finish for the fence shall be Sherwin Williams Powdura® 4000 Super Durable TGIC Free Polyester, medium gloss, applied to over 2 mils thickness and complying with AAMA 2604.
 - An additional clear-coat finish over the powder coating is not required.
 - The proposed man gate shall be self-closing with closing rate controlled hinges (hydraulic) and child proof automatic latch (Manga Latch)
 - Fencing Hardware (i.e. fasteners) shall be 18-8 stainless steel conforming to ASTM A276
 - The number of art panels (i.e. hand painted design motifs) will be dictated by the actual fence layout, in accordance conceptual plan using two fill in panels between the design hand painted panels (see below)



3. Is there Sunset Point Park playground plan?



CITY OF TAMARAC
PURCHASING AND CONTRACTS DIVISION
7525 NW 88TH AVENUE
TAMARAC, FL 33321
"Committed to Excellence...Always"

See bid package 17-05B

4. Are you going to provide design drawings/plans of panels?


See bid package 17-05B

5. What will be the system for mounting posts? According to specs to be mounted over the existing perimeter concrete header curb/sidewalk

See bid package 17-05B pages 11 - 12

6. With 6"x6" plates and anchors. Do you have detailed drawings of this anchorage? With dimensions of embed, depth, etc

See picture below:




Please return and/or acknowledge this Addendum No.3 with your bid submittal due **01/19/2016 at 3:00 PM local time to Tamarac City Hall, RM 108, 7525 NW 88th Ave., Tamarac, FL 33321.**

Sincerely,

Andrew J. Rozwadowski
Senior Procurement Specialist

Please Acknowledge Receipt and Review of this Addendum:



CITY OF TAMARAC
PURCHASING AND CONTRACTS DIVISION
7525 NW 88TH AVENUE
TAMARAC, FL 33321
"Committed to Excellence...Always"

Company Name: _____

Authorized Signature: _____ Date: _____

Printed Name: _____